


REV	DATE	ECO	BY	CHK	APP

DESCRIPTION



NOTES:

1. MATERIAL: BASE - PHENOLIC RATING - 150°C RTI CONNECTOR - STEEL STUD W/ TIN PLATED COPPER ALLOY BUSS AND CLIP

P/N	FUSE CLASS	RMS SYM RATING	TORQUE (IN-LBS)	CONNECTOR TYPE	WIRE	UL	CSA
61017J	J	200K	72	STUD-LUG	60/75	E52283 IZLT2	REPORT NO. LR32169

**GOULD** 374 MERRIMAC STREET  
NEWBURYPORT, MA 01950

PRODUCT MANAGER  
SIGN: *Mill 211*  
DATE: 5-27-97

DESIGN ENGINEER  
SIGN: *St-M-D*  
DATE: 5/27/97

FUSE BLOCK,  
600V-100A,  
2 POLE  
CLASS J

OUTLINE DIMENSIONS  
NOT TO BE USED FOR PRODUCTION

700277